



## DATA SHEET

revision date  
24.06.2024

product code

20.01.02.01

20.01.02.01.e

### Central Point CP 200/6FS



WEIGHT	Approx. 165kg
MAX. DIMENSIONS (WxHxD)	620 x 1530 x 675 mm
MAX. NUMBER OF USERS	6
MIN. WATER FLOW FEED	240 l/min
WATER INLET	EXT 2"
WATER OUTLET	EXT 1 1/2"
MAX. WORKING PRESSURE	25 bar
SUPPLY PRESSURE RANGE	2-10 bar
MAX. WATER TEMPERATURE (FEED)	70° C
NOMINAL ENGINE POWER	7.5 kW
BASIC FREQUENCY	50 Hz
NOMINAL VOLTAGE	3 x 380-415D/660-690Y V
NUMBER OF PIECES IN THE PACKAGE	1
NUMBER OF PIECES ON THE PALLET	1



- Equipped with a Grundfos multistage pump - one of the leading manufacturers of such solutions in the world.
- It has a durable and hygienic stainless steel frame.
- Equipped with dry-running protection and overheating.
- It has a automatic venting system
- Equipped with an inverter, which enables flexible operation of the device and reduces energy consumption
- The housing protects against excessive wear of components
- Central Point equipped with a PLC controller with a touch screen
- Possibility of archiving device errors
- Equipped with protection against dry running and too low pressure on the unit supply
- In e-option — full reporting of media consumption.
- The bonding ties used as a permanent element for fastening cables and wires is detectable by a metal detectors or X-Ray devices.

#### Additional options:

- Possibility to install drivers other than those provided by CleanAccess according to customer requirements
- Possibility of remote connection to a computer and data transfer
- Possibility to install a flow meter and archive water consumption readings
- Possibility to install energy consumption meter
- Possibility of connecting an internet modem in order to remotely connect to the device

### MAINTENANCE

The non-return valve and filter should be checked at least once a month. Depending on the degree of wear, it is recommended to replace them at least once a year.

The Central Point should only be installed in locations where ambient temperature above 0°C is guaranteed. The equipment should be protected against temperatures below freezing, as this may cause water freezing in the system and its damage. If there is a known risk of temperature dropping below freezing, immediately remove all water from the system.